

September 17, 2018

American Promise Group
4366 Military Street
Detroit, MI 48210

**RE: MacDowell Preparatory Academy
4201 W. Outer Dr.
Detroit, MI 48221
Date: September 5, 2018
AEC Project Number: 1515-18002**

Dear Mr. Kochis,

American Environmental Consultants (AEC), LLC conducted lead and copper in water sampling at the MacDowell Preparatory Academy, located at 4201 W. Outer Dr. in Detroit, Michigan. The sampling was conducted on September 5, 2018, by AEC representative, Jef Fox.

Observations

AEC observed the areas to be sampled and no obvious lead components were observed in the portions of the water system that was viewed. AEC attempted to collect samples from randomly targeted locations including but not limited to water main, kitchen faucets, drinking fountains, bathroom faucets, slop sinks and classroom faucets. All samples were collected as a first draw following a rest period of a minimum of 6 hours.

Methodology

The samples were collected utilizing the protocols described in the EPA lead and copper testing guidelines and the 3 T's for Reducing Lead in Drinking Water in Schools: Revised Technical Guidance. The samples were submitted to National Testing Laboratories, Ltd., located at 556 South Mansfield, in Ypsilanti, MI 48197-5166. The phone number to National Testing Laboratories is (440) 449-2525. The samples were analyzed by the EPA Method 200.8. A standard turnaround time was indicated on the chain of custody. A 250 milliliter sample was collected at each point.

Results

The following table summarizes the results from the sampling. The certificates of analysis and chain of custody are attached for further reference.

Number	ID Code	Contaminant	Description	Result	EPA Action Level
1-MA-BR-SS-Cold	270924	Copper	Boiler Room-Slop Sink- Cold	0.002 mg/L	1.3 mg/L
1-MA-BR-SS-Cold	270924	Lead	Boiler Room-Slop Sink- Cold	0.001 mg/L	0.015 mg/L
2-MA-MH-1 st -WC	270922	Copper	Main Hall- 1 st Floor- Water Cooler	0.002 mg/L	1.3 mg/L
2-MA-MH-1 st -WC	270922	Lead	Main Hall- 1 st Floor- Water Cooler	0.001 mg/L	0.015 mg/L
3-MA-MH-1 st -W-DF	270921	Copper	Main Hall- 1 st Floor- West-Drinking Fountain	0.017 mg/L	1.3 mg/L
3-MA-MH-1 st -W-DF	270921	Lead	Main Hall- 1 st Floor- West-Drinking Fountain	0.007 mg/L	0.015 mg/L
4-MA-2 nd -E-DF	270933	Copper	2 nd Floor- East-Drinking Fountain	0.002 mg/L	1.3 mg/L
4-MA-2 nd -E-DF	270933	Lead	2 nd Floor- East-Drinking Fountain	0.001 mg/L	0.015 mg/L
5-MA- 2 nd -E-DF	270928	Copper	2 nd Floor- East-Drinking Fountain	0.002 mg/L	1.3 mg/L
5-MA-2 nd -E-DF	270928	Lead	2 nd Floor- East-Drinking Fountain	0.001 mg/L	0.015 mg/L
6-MA-KF-CW	270930	Copper	Kitchen Faucet-Cold Water	0.540 mg/L	1.3 mg/L

Number	ID Code	Contaminant	Description	Result	EPA Action Level
6-MA-KF-CW	270930	Lead	Kitchen Faucet-Cold Water	0.002 mg/L	0.015 mg/L

Samples collected were found to be below the EPA Action Level for both lead and copper.

Conclusion

No elevated lead and copper in water were identified when compared to the standard.

Limitations

The information and opinions obtained in this report are for the exclusive use of AEC's Client. No distribution to or reliance by other parties may occur without the express written permission of AEC. AEC will not distribute this report without your written consent or as required by law or Court order. The information and opinions that are contained in this report are given in light of that assignment. The report must be reviewed and relied upon only in conjunction with the terms and conditions expressly agreed upon by the parties and as limited therein. Any third parties who have been extended the right to rely on the contents of this report by AEC (which is expressly required prior to any third party release), expressly agrees to be bound by the original terms and conditions entered into by AEC and Client.

Subject to the above terms and conditions, AEC accepts responsibility for the competent performance of its duties in executing the assignment and preparing reports in accordance with the normal standards of the profession, but disclaims any responsibility for consequential damages. Although AEC believes that the results contained herein are reliable, AEC cannot warrant or guarantee that the information provided is exhaustive or that the information provided by Client or third parties is complete or accurate.

AEC appreciates the opportunity to be of service to your organization and looks forward to working with you on future projects. If you have any questions regarding this report please feel free to contact us at our office at 313-491-2600.

Sincerely,
American Environmental Consultants, LLC

A handwritten signature in black ink, appearing to read "Jef Fox". The signature is written in a cursive, flowing style.

Jef Fox
Project Manager

Laboratory ID: 0055

National Testing Laboratories, Ltd
556 South Mansfield, Ypsilanti, MI, 48197-5166
(440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 385293
9/11/2018

Customer: American Environmental Consultants
Jeff Fox
14301 Meyers
Detroit, MI 48227

Source: MacDowell Prep Academy,
270924, 1-MA-BR-SS-Cold
Source City: Detroit
Source State: MI

Date/Time Received: 9/6/2018 10:07
Collected by: J. Fox

The results herein conform to TNI and ISO/IEC 17025:2005 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

LCR= Lead & Copper Rule

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1022	Copper (LCR)	200.8	1.3	mg/L	0.002	0.120	1	9/5/2018 07:05		9/10/2018
1030	Lead	200.8	0.015	mg/L	0.001	0.001	1	9/5/2018 07:05		9/10/2018

Analyst	Tests
SMG	200.8

Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

Laboratory ID: 0055

National Testing Laboratories, Ltd
556 South Mansfield, Ypsilanti, MI, 48197-5166
(440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 385294

9/11/2018

Customer: American Environmental Consultants
Jeff Fox
14301 Meyers
Detroit, MI 48227

Source: MacDowell Prep Academy,
270922, 2-MA-MH-1st-WC
Source City: Detroit
Source State: MI

Date/Time Received: 9/6/2018 10:07

Collected by: J. Fox

The results herein conform to TNI and ISO/IEC 17025:2005 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

LCR= Lead & Copper Rule

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1022	Copper (LCR)	200.8	1.3	mg/L	0.002	0.078	1	9/5/2018 07:08		9/10/2018
1030	Lead	200.8	0.015	mg/L	0.001	0.004	1	9/5/2018 07:08		9/10/2018

Analyst	Tests
SMG	200.8

Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd
 556 South Mansfield, Ypsilanti, MI, 48197-5166
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 385295
9/11/2018

Customer: American Environmental Consultants
 Jeff Fox
 14301 Meyers
 Detroit, MI 48227

Source: MacDowell Prep Academy,
 270921, 3-MA-MH-1st-W-DF
Source City: Detroit
Source State: MI

Date/Time Received: 9/6/2018 10:07

Collected by: J. Fox

The results herein conform to TNI and ISO/IEC 17025:2005 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

LCR= Lead & Copper Rule

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1022	Copper (LCR)	200.8	1.3	mg/L	0.002	0.017	1	9/5/2018 07:11		9/10/2018
1030	Lead	200.8	0.015	mg/L	0.001	0.007	1	9/5/2018 07:11		9/10/2018

Analyst	Tests
SMG	200.8



Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

Laboratory ID: 0055

National Testing Laboratories, Ltd
556 South Mansfield, Ypsilanti, MI, 48197-5166
(440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 385296

9/11/2018

Customer: American Environmental Consultants
Jeff Fox
14301 Meyers
Detroit, MI 48227

Source:

Source City:
Source State:

MacDowell Prep Academy,
270933, 4-MA-2nd-E-DF
Detroit
MI

Date/Time Received: 9/6/2018 10:07

Collected by: J. Fox

The results herein conform to TNI and ISO/IEC 17025:2005 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

LCR= Lead & Copper Rule

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1022	Copper (LCR)	200.8	1.3	mg/L	0.002	0.007	1	9/5/2018 07:14		9/10/2018
1030	Lead	200.8	0.015	mg/L	0.001	0.002	1	9/5/2018 07:14		9/10/2018

Analyst	Tests
SMG	200.8

Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

Laboratory ID: 0055

National Testing Laboratories, Ltd
556 South Mansfield, Ypsilanti, MI, 48197-5166
(440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 385297

9/11/2018

Customer: American Environmental Consultants
Jeff Fox
14301 Meyers
Detroit, MI 48227

Source: MacDowell Prep Academy,
270928, 5-MA-2nd-E-DF
Source City: Detroit
Source State: MI

Date/Time Received: 9/6/2018 10:07

Collected by: J. Fox

The results herein conform to TNI and ISO/IEC 17025:2005 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

LCR= Lead & Copper Rule

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1022	Copper (LCR)	200.8	1.3	mg/L	0.002	0.010	1	9/5/2018 07:17		9/10/2018
1030	Lead	200.8	0.015	mg/L	0.001	0.002	1	9/5/2018 07:17		9/10/2018

Analyst	Tests
SMG	200.8

Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

Laboratory ID: 0055

National Testing Laboratories, Ltd
556 South Mansfield, Ypsilanti, MI, 48197-5166
(440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 385298

9/11/2018

Customer: American Environmental Consultants
Jeff Fox
14301 Meyers
Detroit, MI 48227

Source: MacDowell Prep Academy, 270930, 6-MA-KF-CW
Source City: Detroit
Source State: MI

Date/Time Received: 9/6/2018 10:07

Collected by: J. Fox

The results herein conform to TNI and ISO/IEC 17025:2005 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

LCR= Lead & Copper Rule

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1022	Copper (LCR)	200.8	1.3	mg/L	0.002	0.540	1	9/5/2018 07:20		9/10/2018
1030	Lead	200.8	0.015	mg/L	0.001	0.002	1	9/5/2018 07:20		9/10/2018

Analyst	Tests
SMG	200.8

Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.



1-800-458-3330

General Compliance

Order Number: 2117310
Order Date: 8/29/2018
Sample Number:



Product: Copper & Lead
Sample Paid: No
Payment Method:
TSR: MRM

Sold To: American Environmental Consultants
Jeff Fox
14301 Meyers
Detroit MI 48227
313-491-2600
jfox@aecmi.net

Date Sampled: 9, 5, 18
Time Sampled: 7:05 Please Use Military Time, e.g. 3:00pm = 15:00

Check Time Zone: [X] EST [] CST [] MST [] PST
Client Name: MACDOWELL PREP ACADEMY

Phone Number: 248-637-0697
Fax Number: -

PWS ID# (if applicable):
Sample ID or Source: 270924 1-MA-BR-SS-COLD

Source Type: [] Spring [] Well [X] Municipal [] Surface
[] Other:

City & State: DETROIT MI
(If Different than Above)

Sample Collected By: [Signature]
(Signature)

Sample Collected By: JEFF FOX
(Please Print)

Form Completed By: JEFF FOX

Additional Comments:

For Laboratory Use ONLY
Lab Accounting Information:
Payment \$:
Check #:
Lab Comments/Special Instructions:
RUSH Samples 3 Day TAT
State Forms:
Lab Sample Information:
Date Received:
Time Received:
Received By:
[] Sample receipt criteria checked & acceptable.
[] Deviations from acceptable sample receipt criteria noted on PSA form.



Quality Water Analysis

1-800-458-3330

General Compliance

Order Number: 2117310
Order Date: 8/29/2018

Sample Number:



Product: Copper & Lead

Sample Paid: No Payment Method:

TSR: MRM

Sold To: American Environmental Consultants
Jeff Fox
14301 Meyers
Detroit MI 48227
313-491-2600
jfox@aecmi.net

Date Sampled: 9/5/18

Time Sampled: 7:08 Please Use Military Time, e.g. 3:00pm = 15:00

Check Time Zone: [X] EST [] CST [] MST [] PST

Client Name: MacDowen Prep Academy

Phone Number: 248-637-0697

Fax Number:

PWS ID# (if applicable):

270922
Sample ID or Source: 2-MA-MH-1st-WC

Source Type: [] Spring [] Well [X] Municipal [] Surface
[] Other:

City & State: Detroit, MI
(If Different than Above)

Sample Collected By: [Signature]
(Signature)

Sample Collected By: JEFF FOX
(Please Print)

Form Completed By: JEFF FOX

Additional Comments:

For Laboratory Use ONLY
Lab Accounting Information:
Payment \$:
Check #:
Lab Comments/Special Instructions:
RUSH Samples 3 Day TAT
State Forms:
Lab Sample Information:
Date Received:
Time Received:
Received By:
[] Sample receipt criteria checked & acceptable.
[] Deviations from acceptable sample receipt criteria noted on PSA form.

National Testing Laboratories, Ltd.

Quality Water Analysis

1-800-458-3330

General Compliance

Order Number: 2117310
 Order Date: 8/29/2018
 Sample Number:
 Product: Copper & Lead
 Sample Paid: No Payment Method:
 TSR: MRM



Sold To:
 American Environmental Consultants
 Jeff Fox
 14301 Meyers
 Detroit MI 48227
 313-491-2600
 jfox@aecmi.net

Date Sampled: 9.5.18
 Time Sampled: 7:11 Please Use Military Time, e.g. 3:00pm = 15:00
 Check Time Zone: EST CST MST PST
 Client Name: Macdowell Prep Academy
 Phone Number: 248-637-0697
 Fax Number: _____

PWS ID# (if applicable): _____
 Sample ID or Source: 270921 3-MA-MH-1st-W-DF
 Source Type: Spring Well Municipal Surface
 Other: _____
 City & State: Detroit, MI
(If Different than Above)

Sample Collected By: [Signature]
(Signature)
 Sample Collected By: JEFF FOX
(Please Print)
 Form Completed By: JEFF FOX

Additional Comments:

For Laboratory Use ONLY	
Lab Accounting Information:	
Payment \$:	_____
Check #:	_____
Lab Comments/Special Instructions:	
RUSH Samples 3 Day TAT	
State Forms:	
Lab Sample Information:	
Date Received:	____/____/____
Time Received:	____:____:____
Received By:	_____
<input type="checkbox"/> Sample receipt criteria checked & acceptable. <input type="checkbox"/> Deviations from acceptable sample receipt criteria noted on PSA form.	

National Testing Laboratories, Ltd.

Quality Water Analysis

1-800-458-3330

General Compliance

Order Number: 2117310

Order Date: 8/29/2018

Sample Number:



Product: Copper & Lead

Sample Paid: No Payment Method:

TSR: MRM

Sold To:
American Environmental Consultants
Jeff Fox
14301 Meyers
Detroit MI 48227
313-491-2600
jfox@aecmi.net

Date Sampled: 9/5/18

Time Sampled: 7:14 Please Use Military Time, e.g. 3:00pm = 15:00

Check Time Zone: EST CST MST PST

Client Name: Mac Dowell Prep Academy

Phone Number: 248-637-0697

Fax Number: _____

PWS ID# (if applicable): _____

Sample ID or Source: 270933 Y-MA-2nd-E-DI

Source Type: Spring Well Municipal Surface
 Other: _____

City & State: Detroit, MI
(If Different than Above)

Sample Collected By: [Signature]
(Signature)

Sample Collected By: JEF FOX
(Please Print)

Form Completed By: JEF FOX

Additional Comments:

For Laboratory Use ONLY

Lab Accounting Information:
Payment \$: _____
Check #: _____

Lab Comments/Special Instructions:

RUSH Samples 3 Day TAT

State Forms:

Lab Sample Information:
Date Received: ____/____/____
Time Received: ____:____:____
Received By: _____
 Sample receipt criteria checked & acceptable.
 Deviations from acceptable sample receipt criteria noted on PSA form.



Quality Water Analysis

1-800-458-3330

General Compliance

Order Number: 2117310

Order Date: 8/29/2018

Sample Number:



Product: Copper & Lead

Sample Paid: No Payment Method:

TSR: MRM

Sold To:
American Environmental Consultants
Jeff Fox
14301 Meyers
Detroit MI 48227
313-491-2600
jfox@aecmi.net

Date Sampled: 9/5/18

Time Sampled: 7:17 Please Use Military Time, e.g. 3:00pm = 15:00

Check Time Zone: EST CST MST PST

Client Name: McDowell Prep Academy

Phone Number: 248-637-0697

Fax Number: _____

PWS ID# (if applicable): _____

Sample ID or Source: 270928 S-MA-240-E-DF

Source Type: Spring Well Municipal Surface
 Other: _____

City & State: DETROIT, MI
(If Different than Above)

Sample Collected By: [Signature]
(Signature)

Sample Collected By: JEFF FOX
(Please Print)

Form Completed By: JEFF FOX

Additional Comments:

For Laboratory Use ONLY	
Lab Accounting Information:	
Payment \$:	_____
Check #:	_____
Lab Comments/Special Instructions:	
RUSH Samples 3 Day TAT	
State Forms:	
Lab Sample Information:	
Date Received:	____/____/____
Time Received:	____:____
Received By:	_____
<input type="checkbox"/> Sample receipt criteria checked & acceptable. <input type="checkbox"/> Deviations from acceptable sample receipt criteria noted on PSA form.	

National Testing Laboratories, Ltd.

Quality Water Analysis

1-800-458-3330

General Compliance

Order Number: 2117310

Order Date: 8/29/2018

Sample Number:



Product: Copper & Lead

Sample Paid: No Payment Method:

TSR: MRM

Sold To:
American Environmental Consultants
Jeff Fox
14301 Meyers
Detroit MI 48227
313-491-2600
jfox@aecmi.net

Date Sampled: 9.5.18

Time Sampled: 7:20 Please Use Military Time, e.g. 3:00pm = 15:00

Check Time Zone: EST CST MST PST

Client Name: MacDowall Prop Addition 7

Phone Number: 248-637-0697

Fax Number: _____

PWS ID# (if applicable): _____

Sample ID or Source: 270930 6-MA-KF-CW

Source Type: Spring Well Municipal Surface
 Other: _____

City & State: DETROIT, MI
(If Different than Above)

Sample Collected By: [Signature]
(Signature)

Sample Collected By: JEFF FOX
(Please Print)

Form Completed By: Jeff Fox

Additional Comments:

For Laboratory Use ONLY	
Lab Accounting Information:	
Payment \$:	_____
Check #:	_____
Lab Comments/Special Instructions:	
RUSH Samples 3 Day TAT	
State Forms:	
Lab Sample Information:	
Date Received:	____/____/____
Time Received:	____:____
Received By:	_____
<input type="checkbox"/> Sample receipt criteria checked & acceptable. <input type="checkbox"/> Deviations from acceptable sample receipt criteria noted on PSA form.	